

AFFIDAVIT SELF-CERTIFICATION FOR COMPLIANCE OF SMOKE DETECTORS AND CARBON MONOXIDE ALARMS

THE CERTIFICATION MUST BE COMPLETE AND RETURNED TO THE CITY OF FREMONT BUILDING INSPECTOR PRIOR TO FINAL SIGN-OFF OF ALL PERMITS REQUIRING COMPLIANCE.

When the valuation of additions, alterations, or repairs to dwelling units exceeds \$1,000.00 smoke detectors shall be installed in each sleeping room, and outside each separate sleeping area in the immediate vicinity of the bedrooms, and on each additional story of the dwelling, including basements and habitable attics as required by Section R314, of the 2013 California Residential Code (CRC).

For dwellings or sleeping units containing fuel burning appliances or having attached garages, carbon monoxide detectors shall be installed outside each separate sleeping area in the immediate vicinity of the bedrooms, and on each additional story of the dwelling, including basements as required by Section R315 of the 2013 CRC.

All alarms shall comply with requirements for listing and approval by the Office of the State Fire Marshal.

Property Address:	Fremont, CA
Building Permit Number: BLD20	
Total # of Bedrooms:	
Total # of Floors:	(Including Habitable Basements and Attic Spaces)
TOTAL Number of Smoke	Alarms in Dwelling Unit:
TOTAL Number of Carbon	Monoxide Alarms in Dwelling Unit:
detectors and carbon monoxide detector	roperty, I hereby certify that I have installed the smoke ors in accordance with the manufacturer's instructions and s of the California Residential Code, California Building Code.
	that the foregoing is true and correct, and that this at Fremont, California.
Owner's Name (printed/typed):	
Signature of Owner	

RESIDENTIAL SMOKE AND CARBON MONOXIDE ALARM REQUIREMENTS

Effective January 1, 2011, all residential permit exceeding \$1,000 in valuation shall be required to install smoke and carbon monoxide detectors throughout the residence. Smoke and carbon monoxide detectors shall be installed in accordance with the 2013 California Residential Code (CRC) and shall be verified at the permit final.

Smoke alarms shall be tested and maintained in accordance with the manufacturer's instructions. Smoke alarms shall be replaced after 10 years from the date of manufacture marked on the unit, or if the date of manufacture cannot be determined.

Smoke alarms shall be installed in the following locations:

- 1. In each sleeping room.
- 2. Outside each separate sleeping area in the immediate vicinity of the bedrooms.
- 3. On each additional story of the dwelling, including basements ad habitable attics but not including crawl spaces and uninhabitable attics.

Carbon monoxide alarms shall be installed in the following locations:

- 1. Outside of each separate dwelling unit sleeping area in the immediate vicinity of the bedroom(s).
- 2. On every level of a dwelling unit including basements.

